

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-------------|------------|------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | W2022000139 | 2022000259 | WTP01 - Raw | 1/02/2022 | 0.007 |
| NSW Health Pathology (FASS) | W2022000139 | 2022000260 | WTP02 - Settled | 1/02/2022 | 0.001 |
| NSW Health Pathology (FASS) | W2022000139 | 2022000261 | WTP06 - Filtered | 1/02/2022 | 0.001 |
| NSW Health Pathology (FASS) | W2022000096 | 2022000178 | WTP01 - Raw | 18/01/2022 | 0.006 |
| NSW Health Pathology (FASS) | W2022000096 | 2022000179 | WTP02 - Settled | 18/01/2022 | 0.001 |
| NSW Health Pathology (FASS) | W2022000096 | 2022000180 | WTP06 - Filtered | 18/01/2022 | 0.001 |
| NSW Health Pathology (FASS) | W2022000009 | 2022000014 | WTP01 - Raw | 4/01/2022 | 0.008 |
| NSW Health Pathology (FASS) | W2022000009 | 2022000015 | WTP02 - Settled | 4/01/2022 | 0.001 |
| NSW Health Pathology (FASS) | W2022000009 | 2022000016 | WTP06 - Filtered | 4/01/2022 | 0.001 |
| NSW Health Pathology (FASS) | W2021001659 | 2021002932 | WTP01 - Raw | 14/12/2021 | 0.004 |
| NSW Health Pathology (FASS) | W2021001659 | 2021002933 | WTP02 - Settled | 14/12/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001659 | 2021002934 | WTP06 - Filtered | 14/12/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001554 | 2021002752 | WTP01 - Raw | 30/11/2021 | 0.004 |
| NSW Health Pathology (FASS) | W2021001554 | 2021002754 | WTP02 - Settled | 30/11/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001554 | 2021002753 | WTP06 - Filtered | 30/11/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001406 | 2021002507 | WTP01 - Raw | 2/11/2021 | 0.010 |
| NSW Health Pathology (FASS) | W2021001406 | 2021002508 | WTP02 - Settled | 2/11/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001406 | 2021002509 | WTP06 - Filtered | 2/11/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001263 | 2021002225 | WTP01 - Raw | 5/10/2021 | 0.003 |
| NSW Health Pathology (FASS) | W2021001263 | 2021002226 | WTP02 - Settled | 5/10/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021001263 | 2021002227 | WTP06 - Filtered | 5/10/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021001211 | 2021002142 | WTP01 - Raw | 21/09/2021 | 0.005 |
| NSW Health Pathology (FASS) | W2021001211 | 2021002143 | WTP02 - Settled | 21/09/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001211 | 2021002144 | WTP06 - Filtered | 21/09/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001122 | 2021001986 | WTP01 - Raw | 7/09/2021 | 0.004 |
| NSW Health Pathology (FASS) | W2021001122 | 2021001987 | WTP02 - Settled | 7/09/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001122 | 2021001988 | WTP06 - Filtered | 7/09/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021001088 | 2021001931 | WTP01 - Raw | 24/08/2021 | 0.005 |
| NSW Health Pathology (FASS) | W2021001088 | 2021001932 | WTP02 - Settled | 24/08/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021001088 | 2021001933 | WTP06 - Filtered | 24/08/2021 | 0.001 |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-------------|------------|------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | W2021001063 | 2021001894 | WTP01 - Raw | 10/08/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021001063 | 2021001895 | WTP02 - Settled | 10/08/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021001063 | 2021001896 | WTP06 - Filtered | 10/08/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000970 | 2021001732 | WTP01 - Raw | 27/07/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000970 | 2021001733 | WTP02 - Settled | 27/07/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000970 | 2021001734 | WTP06 - Filtered | 27/07/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000927 | 2021001670 | WTP01 - Raw | 13/07/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000927 | 2021001672 | WTP02 - Settled | 13/07/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000927 | 2021001671 | WTP06 - Filtered | 13/07/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000834 | 2021001514 | WTP01 - Raw | 29/06/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000834 | 2021001515 | WTP02 - Settled | 29/06/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000834 | 2021001516 | WTP06 - Filtered | 29/06/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000813 | 2021001476 | WTP01 - Raw | 15/06/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000813 | 2021001477 | WTP02 - Settled | 15/06/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000813 | 2021001478 | WTP06 - Filtered | 15/06/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000718 | 2021001321 | WTP01 - Raw | 1/06/2021 | 0.010 |
| NSW Health Pathology (FASS) | W2021000718 | 2021001322 | WTP02 - Settled | 1/06/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000718 | 2021001323 | WTP06 - Filtered | 1/06/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000687 | 2021001267 | WTP01 - Raw | 18/05/2021 | 0.012 |
| NSW Health Pathology (FASS) | W2021000687 | 2021001268 | WTP02 - Settled | 18/05/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000687 | 2021001269 | WTP06 - Filtered | 18/05/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000575 | 2021001061 | WTP01 - Raw | 4/05/2021 | 0.009 |
| NSW Health Pathology (FASS) | W2021000575 | 2021001062 | WTP02 - Settled | 4/05/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000575 | 2021001063 | WTP06 - Filtered | 4/05/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000534 | 2021000960 | WTP01 - Raw | 20/04/2021 | 0.009 |
| NSW Health Pathology (FASS) | W2021000534 | 2021000961 | WTP02 - Settled | 20/04/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000534 | 2021000962 | WTP06 - Filtered | 20/04/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000439 | 2021000811 | WTP01 - Raw | 6/04/2021 | 0.009 |
| NSW Health Pathology (FASS) | W2021000439 | 2021000812 | WTP02 - Settled | 6/04/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000439 | 2021000813 | WTP06 - Filtered | 6/04/2021 | 0.001 |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-------------|------------|------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | W2021000410 | 2021000745 | WTP01 - Raw | 23/03/2021 | 0.010 |
| NSW Health Pathology (FASS) | W2021000410 | 2021000746 | WTP02 - Settled | 23/03/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000410 | 2021000747 | WTP06 - Filtered | 23/03/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000370 | 2021000669 | WTP01 - Raw | 9/03/2021 | 0.010 |
| NSW Health Pathology (FASS) | W2021000370 | 2021000670 | WTP02 - Settled | 9/03/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000370 | 2021000671 | WTP06 - Filtered | 9/03/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000277 | 2021000495 | WTP01 - Raw | 23/02/2021 | 0.016 |
| NSW Health Pathology (FASS) | W2021000277 | 2021000496 | WTP02 - Settled | 23/02/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000277 | 2021000497 | WTP06 - Filtered | 23/02/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000219 | 2021000381 | WTP01 - Raw | 9/02/2021 | 0.018 |
| NSW Health Pathology (FASS) | W2021000219 | 2021000382 | WTP02 - Settled | 9/02/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000219 | 2021000383 | WTP06 - Filtered | 9/02/2021 | 0.002 |
| NSW Health Pathology (FASS) | W2021000100 | 2021000173 | WTP01 - Raw | 19/01/2021 | 0.014 |
| NSW Health Pathology (FASS) | W2021000100 | 2021000174 | WTP02 - Settled | 19/01/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000100 | 2021000175 | WTP06 - Filtered | 19/01/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2021000025 | 2021000049 | WTP01 - Raw | 5/01/2021 | 0.007 |
| NSW Health Pathology (FASS) | W2021000025 | 2021000050 | WTP02 - Settled | 5/01/2021 | <0.001 |
| NSW Health Pathology (FASS) | W2021000025 | 2021000051 | WTP06 - Filtered | 5/01/2021 | 0.001 |
| NSW Health Pathology (FASS) | W2020001762 | 2020003463 | WTP01 - Raw | 1/12/2020 | 0.011 |
| NSW Health Pathology (FASS) | W2020001762 | 2020003466 | WTP01 - Raw | 1/12/2020 | 0.011 |
| NSW Health Pathology (FASS) | W2020001762 | 2020003464 | WTP02 - Settled | 1/12/2020 | 0.002 |
| NSW Health Pathology (FASS) | W2020001762 | 2020003467 | WTP02 - Settled | 1/12/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001762 | 2020003465 | WTP06 - Filtered | 1/12/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001762 | 2020003468 | WTP06 - Filtered | 1/12/2020 | 0.002 |
| NSW Health Pathology (FASS) | W2020001676 | 2020003289 | WTP01 - Raw | 17/11/2020 | 0.010 |
| NSW Health Pathology (FASS) | W2020001676 | 2020003290 | WTP02 - Settled | 17/11/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001676 | 2020003291 | WTP06 - Filtered | 17/11/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001597 | 2020003167 | WTP01 - Raw | 3/11/2020 | - |
| NSW Health Pathology (FASS) | W2020001597 | 2020003168 | WTP02 - Settled | 3/11/2020 | - |
| NSW Health Pathology (FASS) | W2020001597 | 2020003169 | WTP03 - Final | 3/11/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-------------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | W2020001524 | 2020003031 | WTP01 - Raw | 20/10/2020 | - |
| NSW Health Pathology (FASS) | W2020001524 | 2020003032 | WTP02 - Settled | 20/10/2020 | - |
| NSW Health Pathology (FASS) | W2020001524 | 2020003033 | WTP06 - Filtered | 20/10/2020 | - |
| NSW Health Pathology (FASS) | W2020001459 | 2020002911 | WTP01 - Raw | 6/10/2020 | 0.005 |
| NSW Health Pathology (FASS) | W2020001459 | 2020002912 | WTP02 - Settled | 6/10/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001459 | 2020002913 | WTP06 - Filtered | 6/10/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001343 | 2020002704 | WTP01 - Raw | 8/09/2020 | 0.003 |
| NSW Health Pathology (FASS) | W2020001343 | 2020002705 | WTP02 - Settled | 8/09/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001343 | 2020002706 | WTP06 - Filtered | 8/09/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001253 | 2020002564 | WTP01 - Raw | 25/08/2020 | 0.003 |
| NSW Health Pathology (FASS) | W2020001253 | 2020002566 | WTP03 - Final | 25/08/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020001253 | 2020002565 | WTP06 - Filtered | 25/08/2020 | 0.001 |
| NSW Health Pathology (FASS) | W2020000927 | 2020001970 | WTP01 - Raw | 16/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000927 | 2020001972 | WTP03 - Final | 16/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000927 | 2020001971 | WTP06 - Filtered | 16/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000843 | 2020001828 | WTP04 - Retic - Depot | 2/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000843 | 2020001825 | WTP05 - Retic - Sport Complex | 2/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000843 | 2020001826 | WTP07 - Alma Park | 2/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000843 | 2020001824 | WTP09 - Fire Station | 2/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000843 | 2020001827 | WTP11 - Warwick Street | 2/06/2020 | - |
| NSW Health Pathology (FASS) | W2020000800 | 2020001736 | WTP04 - Retic - Depot | 17/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000800 | 2020001734 | WTP05 - Retic - Sport Complex | 17/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000800 | 2020001735 | WTP07 - Alma Park | 17/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000800 | 2020001738 | WTP09 - Fire Station | 17/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000800 | 2020001737 | WTP11 - Warwick Street | 17/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000791 | 2020001712 | WTP04 - Retic - Depot | 13/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000791 | 2020001715 | WTP05 - Retic - Sport Complex | 13/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000791 | 2020001713 | WTP07 - Alma Park | 13/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000791 | 2020001716 | WTP09 - Fire Station | 13/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000791 | 2020001714 | WTP11 - Warwick Street | 13/05/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-------------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | W2020000776 | 2020001690 | WTP01 - Raw | 12/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000776 | 2020001691 | WTP02 - Settled | 12/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000776 | 2020001692 | WTP06 - Filtered | 12/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000705 | 2020001570 | WTP01 - Raw | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000705 | 2020001572 | WTP02 - Settled | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000705 | 2020001573 | WTP03 - Final | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000705 | 2020001571 | WTP04 - Retic - Depot | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000706 | 2020001577 | WTP05 - Retic - Sport Complex | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000706 | 2020001576 | WTP07 - Alma Park | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000706 | 2020001574 | WTP09 - Fire Station | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000706 | 2020001575 | WTP11 - Warwick Street | 5/05/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001532 | WTP01 - Raw | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001533 | WTP02 - Settled | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001534 | WTP03 - Final | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001528 | WTP04 - Retic - Depot | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001531 | WTP05 - Retic - Sport Complex | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001529 | WTP07 - Alma Park | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001530 | WTP09 - Fire Station | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000687 | 2020001527 | WTP11 - Warwick Street | 28/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000673 | 2020001496 | WTP01 - Raw | 22/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000673 | 2020001497 | WTP02 - Settled | 22/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000673 | 2020001498 | WTP03 - Final | 22/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000660 | 2020001474 | WTP04 - Retic - Depot | 21/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000660 | 2020001472 | WTP05 - Retic - Sport Complex | 21/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000660 | 2020001473 | WTP07 - Alma Park | 21/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000660 | 2020001470 | WTP09 - Fire Station | 21/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000660 | 2020001471 | WTP11 - Warwick Street | 21/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000627 | 2020001416 | WTP01 - Raw | 14/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000627 | 2020001417 | WTP02 - Settled | 14/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000627 | 2020001418 | WTP03 - Final | 14/04/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-------------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | W2020000626 | 2020001413 | WTP04 - Retic - Depot | 14/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000626 | 2020001411 | WTP05 - Retic - Sport Complex | 14/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000626 | 2020001412 | WTP07 - Alma Park | 14/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000626 | 2020001415 | WTP09 - Fire Station | 14/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000626 | 2020001414 | WTP11 - Warwick Street | 14/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000623 | 2020001402 | WTP01 - Raw | 8/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000623 | 2020001403 | WTP02 - Settled | 8/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000621 | 2020001398 | WTP04 - Retic - Depot | 8/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000621 | 2020001396 | WTP05 - Retic - Sport Complex | 8/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000621 | 2020001397 | WTP07 - Alma Park | 8/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000621 | 2020001400 | WTP09 - Fire Station | 8/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000621 | 2020001399 | WTP11 - Warwick Street | 8/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000595 | 2020001315 | WTP01 - Raw | 7/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000595 | 2020001316 | WTP02 - Settled | 7/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000595 | 2020001317 | WTP03 - Final | 7/04/2020 | - |
| NSW Health Pathology (FASS) | W2020000540 | 2020001185 | WTP01 - Raw | 31/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000540 | 2020001187 | WTP02 - Settled | 31/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000540 | 2020001186 | WTP03 - Final | 31/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000534 | 2020001176 | WTP01 - Raw | 30/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000534 | 2020001174 | WTP02 - Settled | 30/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000534 | 2020001175 | WTP03 - Final | 30/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000529 | 2020001164 | WTP01 - Raw | 26/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000529 | 2020001166 | WTP02 - Settled | 26/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000529 | 2020001165 | WTP03 - Final | 26/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000526 | 2020001158 | WTP01 - Raw | 25/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000526 | 2020001160 | WTP02 - Settled | 25/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000526 | 2020001159 | WTP03 - Final | 25/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000518 | 2020001147 | WTP01 - Raw | 24/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000518 | 2020001149 | WTP02 - Settled | 24/03/2020 | - |
| NSW Health Pathology (FASS) | W2020000518 | 2020001148 | WTP03 - Final | 24/03/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020001117 | WTP01 - Raw | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001118 | WTP02 - Settled | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001119 | WTP03 - Final | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001114 | WTP04 - Retic - Depot | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001112 | WTP05 - Retic - Sport Complex | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001113 | WTP07 - Alma Park | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001116 | WTP09 - Fire Station | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001115 | WTP11 - Warwick Street | 19/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001069 | WTP01 - Raw | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001071 | WTP02 - Settled | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001070 | WTP03 - Final | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001066 | WTP04 - Retic - Depot | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001064 | WTP05 - Retic - Sport Complex | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001065 | WTP07 - Alma Park | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001068 | WTP09 - Fire Station | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001067 | WTP11 - Warwick Street | 16/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001047 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001048 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001049 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001050 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001051 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001052 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001053 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001054 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001055 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001056 | WTP01 - Raw | 13/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001045 | WTP01 - Raw | 12/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001046 | WTP03 - Final | 12/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001042 | WTP04 - Retic - Depot | 12/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001040 | WTP05 - Retic - Sport Complex | 12/03/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020001041 | WTP07 - Alma Park | 12/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001044 | WTP09 - Fire Station | 12/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020001043 | WTP11 - Warwick Street | 12/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000978 | WTP02 - Settled | 10/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000975 | WTP04 - Retic - Depot | 10/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000973 | WTP05 - Retic - Sport Complex | 10/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000974 | WTP07 - Alma Park | 10/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000977 | WTP09 - Fire Station | 10/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000976 | WTP11 - Warwick Street | 10/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000972 | WTP02 - Settled | 9/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000969 | WTP04 - Retic - Depot | 9/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000967 | WTP05 - Retic - Sport Complex | 9/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000968 | WTP07 - Alma Park | 9/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000971 | WTP09 - Fire Station | 9/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000970 | WTP11 - Warwick Street | 9/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000934 | WTP04 - Retic - Depot | 6/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000932 | WTP05 - Retic - Sport Complex | 6/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000933 | WTP07 - Alma Park | 6/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000936 | WTP09 - Fire Station | 6/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000935 | WTP11 - Warwick Street | 6/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000885 | WTP04 - Retic - Depot | 4/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000883 | WTP05 - Retic - Sport Complex | 4/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000884 | WTP07 - Alma Park | 4/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000887 | WTP09 - Fire Station | 4/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000886 | WTP11 - Warwick Street | 4/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000831 | WTP01 - Raw | 3/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000832 | WTP03 - Final | 3/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000835 | WTP04 - Retic - Depot | 3/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000834 | WTP07 - Alma Park | 3/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000833 | WTP10 - King Street | 3/03/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020000816 | WTP01 - Raw | 2/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000817 | WTP03 - Final | 2/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000820 | WTP04 - Retic - Depot | 2/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000819 | WTP07 - Alma Park | 2/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000818 | WTP10 - King Street | 2/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000813 | WTP01 - Raw | 1/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000809 | WTP03 - Final | 1/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000812 | WTP04 - Retic - Depot | 1/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000810 | WTP07 - Alma Park | 1/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000811 | WTP10 - King Street | 1/03/2020 | - |
| NSW Health Pathology (FASS) | | 2020000792 | WTP01 - Raw | 25/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000791 | WTP03 - Final | 25/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000788 | WTP04 - Retic - Depot | 25/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000786 | WTP05 - Retic - Sport Complex | 25/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000787 | WTP07 - Alma Park | 25/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000790 | WTP09 - Fire Station | 25/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000789 | WTP11 - Warwick Street | 25/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000709 | Retic 1 | 18/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000710 | Retic 2 | 18/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000711 | Retic 3 | 18/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000712 | Retic 4 | 18/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000713 | Retic 5 | 18/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000708 | WTP01 - Raw | 18/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000707 | WTP03 - Final | 18/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000614 | WTP01 - Raw | 11/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000615 | WTP02 - Settled | 11/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000616 | WTP03 - Final | 11/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000617 | WTP04 - Retic - Depot | 11/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000618 | WTP05 - Retic - Sport Complex | 11/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000469 | TP01 | 4/02/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020000470 | TP02 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000471 | TP03 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000472 | TP04 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000473 | TP05 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000474 | TP06 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000475 | TP07 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000476 | TP08 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000477 | TP09 | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000478 | WTP01 - Raw | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000479 | WTP02 - Settled | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000480 | WTP03 - Final | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000481 | WTP04 - Retic - Depot | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000482 | WTP05 - Retic - Sport Complex | 4/02/2020 | - |
| NSW Health Pathology (FASS) | | 2020000389 | TP01 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000390 | TP02 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000391 | TP03 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000392 | TP04 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000393 | TP05 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000394 | TP06 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000395 | TP07 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000396 | TP08 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000397 | TP09 | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000398 | WTP01 - Raw | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000399 | WTP02 - Settled | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000402 | WTP04 - Retic - Depot | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000401 | WTP05 - Retic - Sport Complex | 28/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP01 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP02 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP03 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP04 | 23/01/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020000349 | TP05 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP06 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP07 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP08 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000349 | TP09 | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000358 | WTP01 - Raw | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000359 | WTP02 - Settled | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000360 | WTP03 - Final | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000362 | WTP04 - Retic - Depot | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000363 | WTP05 - Retic - Sport Complex | 23/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000339 | WTP01 - Raw | 21/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000337 | WTP02 - Settled | 21/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000338 | WTP03 - Final | 21/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000299 | WTP01 - Raw | 17/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000296 | WTP02 - Settled | 17/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000298 | WTP03 - Final | 17/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000297 | WTP04 - Retic - Depot | 17/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000295 | WTP05 - Retic - Sport Complex | 17/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000294 | WTP01 - Raw | 16/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000291 | WTP02 - Settled | 16/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000293 | WTP03 - Final | 16/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000292 | WTP04 - Retic - Depot | 16/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000290 | WTP05 - Retic - Sport Complex | 16/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000272 | WTP01 - Raw | 15/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000269 | WTP02 - Settled | 15/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000271 | WTP03 - Final | 15/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000268 | WTP04 - Retic - Depot | 15/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000270 | WTP05 - Retic - Sport Complex | 15/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000252 | WTP01 - Raw | 14/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000249 | WTP02 - Settled | 14/01/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020000251 | WTP03 - Final | 14/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000248 | WTP04 - Retic - Depot | 14/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000250 | WTP05 - Retic - Sport Complex | 14/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000232 | WTP01 - Raw | 13/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000235 | WTP02 - Settled | 13/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000236 | WTP03 - Final | 13/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000233 | WTP04 - Retic - Depot | 13/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000234 | WTP05 - Retic - Sport Complex | 13/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000227 | WTP01 - Raw | 12/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000230 | WTP02 - Settled | 12/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000231 | WTP03 - Final | 12/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000228 | WTP04 - Retic - Depot | 12/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000229 | WTP05 - Retic - Sport Complex | 12/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000220 | WTP01 - Raw | 10/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000221 | WTP02 - Settled | 10/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000222 | WTP03 - Final | 10/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000224 | WTP04 - Retic - Depot | 10/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000223 | WTP05 - Retic - Sport Complex | 10/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000093 | WTP01 - Raw | 7/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000090 | WTP02 - Settled | 7/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000092 | WTP03 - Final | 7/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000091 | WTP05 - Retic - Sport Complex | 7/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000084 | WTP01 - Raw | 6/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000082 | WTP02 - Settled | 6/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000083 | WTP03 - Final | 6/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000080 | WTP04 - Retic - Depot | 6/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000081 | WTP05 - Retic - Sport Complex | 6/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000079 | WTP01 - Raw | 5/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000077 | WTP02 - Settled | 5/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000078 | WTP03 - Final | 5/01/2020 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020000075 | WTP04 - Retic - Depot | 5/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000076 | WTP05 - Retic - Sport Complex | 5/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000049 | WTP01 - Raw | 3/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000050 | WTP01 - Raw | 3/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000048 | WTP06 - Filtered | 3/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000028 | TP01 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000029 | TP02 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000030 | TP03 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000031 | TP04 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000032 | TP05 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000033 | TP06 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000034 | TP07 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000035 | TP09 | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000027 | WTP01 - Raw | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000025 | WTP02 - Settled | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000026 | WTP03 - Final | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000023 | WTP04 - Retic - Depot | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000024 | WTP05 - Retic - Sport Complex | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000047 | WTP06 - Filtered | 2/01/2020 | - |
| NSW Health Pathology (FASS) | | 2020000022 | WTP01 - Raw | 31/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000020 | WTP02 - Settled | 31/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000021 | WTP03 - Final | 31/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000018 | WTP04 - Retic - Depot | 31/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000019 | WTP05 - Retic - Sport Complex | 31/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000015 | WTP01 - Raw | 30/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000017 | WTP01 - Raw | 30/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000013 | WTP02 - Settled | 30/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000014 | WTP03 - Final | 30/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000011 | WTP04 - Retic - Depot | 30/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000012 | WTP05 - Retic - Sport Complex | 30/12/2019 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2020000010 | WTP01 - Raw | 29/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000008 | WTP02 - Settled | 29/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000009 | WTP03 - Final | 29/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000006 | WTP04 - Retic - Depot | 29/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000007 | WTP05 - Retic - Sport Complex | 29/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000005 | WTP01 - Raw | 28/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000003 | WTP02 - Settled | 28/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000004 | WTP03 - Final | 28/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000001 | WTP04 - Retic - Depot | 28/12/2019 | - |
| NSW Health Pathology (FASS) | | 2020000002 | WTP05 - Retic - Sport Complex | 28/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003304 | TP01 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003305 | TP02 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003306 | TP03 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003307 | TP04 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003308 | TP05 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003309 | TP06 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003310 | TP07 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003311 | TP08 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003312 | TP09 | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003297 | WTP01 - Raw | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003295 | WTP02 - Settled | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003296 | WTP03 - Final | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003294 | WTP04 - Retic - Depot | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003298 | WTP05 - Retic - Sport Complex | 27/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003302 | WTP01 - Raw | 26/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003303 | WTP02 - Settled | 26/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003301 | WTP03 - Final | 26/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003299 | WTP04 - Retic - Depot | 26/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003300 | WTP05 - Retic - Sport Complex | 26/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003293 | WTP01 - Raw | 25/12/2019 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2019003290 | WTP02 - Settled | 25/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003292 | WTP03 - Final | 25/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003291 | WTP04 - Retic - Depot | 25/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003289 | WTP05 - Retic - Sport Complex | 25/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003277 | WTP01 - Raw | 23/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003283 | WTP02 - Settled | 23/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003280 | WTP03 - Final | 23/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003271 | WTP04 - Retic - Depot | 23/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003274 | WTP05 - Retic - Sport Complex | 23/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003276 | WTP01 - Raw | 22/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003282 | WTP02 - Settled | 22/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003279 | WTP03 - Final | 22/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003270 | WTP04 - Retic - Depot | 22/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003273 | WTP05 - Retic - Sport Complex | 22/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003275 | WTP01 - Raw | 21/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003281 | WTP02 - Settled | 21/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003278 | WTP03 - Final | 21/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003269 | WTP04 - Retic - Depot | 21/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003272 | WTP05 - Retic - Sport Complex | 21/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003265 | WTP01 - Raw | 20/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003267 | WTP02 - Settled | 20/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003266 | WTP03 - Final | 20/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003263 | WTP04 - Retic - Depot | 20/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003264 | WTP05 - Retic - Sport Complex | 20/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003260 | Weir | 19/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003261 | WTP01 - Raw | 19/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003259 | WTP03 - Final | 19/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003257 | WTP04 - Retic - Depot | 19/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003258 | WTP05 - Retic - Sport Complex | 19/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003241 | TP01 | 18/12/2019 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Testing Agency | Report No | Sample ID | Sample Area | Sample Date | Soluble Arsenic Result (mg/L) |
|-----------------------------|-----------|------------|-------------------------------|-------------|-------------------------------|
| NSW Health Pathology (FASS) | | 2019003242 | TP02 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003243 | TP03 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003244 | TP04 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003240 | TP05 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003245 | TP06 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003246 | TP07 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003247 | TP08 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003248 | TP09 | 18/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003211 | WTP01 - Raw | 16/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003210 | WTP03 - Final | 16/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003209 | WTP04 - Retic - Depot | 16/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003208 | WTP05 - Retic - Sport Complex | 16/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003181 | WTP01 - Raw | 12/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003183 | WTP03 - Final | 12/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003180 | WTP04 - Retic - Depot | 12/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003182 | WTP05 - Retic - Sport Complex | 12/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003185 | WTP01 - Raw | 11/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003186 | WTP03 - Final | 11/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003187 | WTP04 - Retic - Depot | 11/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019003184 | WTP05 - Retic - Sport Complex | 11/12/2019 | - |
| NSW Health Pathology (FASS) | | 2019002987 | WTP03 - Final | 26/11/2019 | - |
| NSW Health Pathology (FASS) | | 2019001931 | WTP03 - Final | 13/08/2019 | - |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.008 | 2/02/2022 |
| 0.001 | 2/02/2022 |
| 0.001 | 2/02/2022 |
| 0.007 | 19/01/2022 |
| 0.001 | 19/01/2022 |
| 0.001 | 19/01/2022 |
| 0.009 | 5/01/2022 |
| 0.001 | 5/01/2022 |
| 0.001 | 5/01/2022 |
| 0.005 | 15/12/2021 |
| 0.001 | 15/12/2021 |
| 0.001 | 15/12/2021 |
| 0.005 | 1/12/2021 |
| 0.001 | 1/12/2021 |
| 0.001 | 1/12/2021 |
| 0.011 | 3/11/2021 |
| 0.001 | 3/11/2021 |
| 0.001 | 3/11/2021 |
| 0.004 | 6/10/2021 |
| <0.001 | 6/10/2021 |
| <0.001 | 6/10/2021 |
| 0.006 | 22/09/2021 |
| 0.001 | 22/09/2021 |
| 0.001 | 22/09/2021 |
| 0.005 | 8/09/2021 |
| 0.001 | 8/09/2021 |
| 0.001 | 8/09/2021 |
| 0.006 | 25/08/2021 |
| 0.001 | 25/08/2021 |
| <0.001 | 25/08/2021 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.002 | 11/08/2021 |
| <0.001 | 11/08/2021 |
| <0.001 | 11/08/2021 |
| 0.002 | 28/07/2021 |
| <0.001 | 28/07/2021 |
| <0.001 | 28/07/2021 |
| 0.002 | 14/07/2021 |
| <0.001 | 14/07/2021 |
| <0.001 | 14/07/2021 |
| 0.004 | 30/06/2021 |
| 0.002 | 30/06/2021 |
| 0.002 | 30/06/2021 |
| 0.002 | 16/06/2021 |
| <0.001 | 16/06/2021 |
| <0.001 | 16/06/2021 |
| 0.013 | 2/06/2021 |
| 0.001 | 2/06/2021 |
| 0.001 | 2/06/2021 |
| 0.015 | 19/05/2021 |
| 0.001 | 19/05/2021 |
| 0.001 | 19/05/2021 |
| 0.013 | 5/05/2021 |
| 0.001 | 5/05/2021 |
| <0.001 | 5/05/2021 |
| 0.012 | 21/04/2021 |
| 0.001 | 21/04/2021 |
| 0.001 | 21/04/2021 |
| 0.010 | 7/04/2021 |
| 0.001 | 7/04/2021 |
| 0.003 | 7/04/2021 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.016 | 24/03/2021 |
| 0.001 | 24/03/2021 |
| 0.001 | 24/03/2021 |
| 0.012 | 10/03/2021 |
| 0.001 | 10/03/2021 |
| 0.001 | 10/03/2021 |
| 0.018 | 24/02/2021 |
| 0.002 | 24/02/2021 |
| 0.002 | 24/02/2021 |
| 0.019 | 10/02/2021 |
| 0.003 | 10/02/2021 |
| 0.003 | 10/02/2021 |
| 0.018 | 21/01/2021 |
| 0.005 | 21/01/2021 |
| 0.006 | 21/01/2021 |
| 0.008 | 6/01/2021 |
| 0.001 | 6/01/2021 |
| <0.001 | 6/01/2021 |
| 0.013 | 3/12/2020 |
| 0.012 | 3/12/2020 |
| 0.002 | 3/12/2020 |
| 0.002 | 3/12/2020 |
| 0.001 | 3/12/2020 |
| 0.001 | 3/12/2020 |
| 0.011 | 18/11/2020 |
| 0.001 | 18/11/2020 |
| 0.001 | 18/11/2020 |
| 0.009 | 4/11/2020 |
| 0.001 | 4/11/2020 |
| 0.001 | 4/11/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.006 | 21/10/2020 |
| 0.002 | 21/10/2020 |
| 0.001 | 21/10/2020 |
| 0.006 | 8/10/2020 |
| 0.001 | 8/10/2020 |
| 0.001 | 8/10/2020 |
| 0.005 | 9/09/2020 |
| 0.001 | 9/09/2020 |
| <0.001 | 9/09/2020 |
| 0.005 | 26/08/2020 |
| 0.001 | 26/08/2020 |
| 0.001 | 26/08/2020 |
| 0.005 | 17/06/2020 |
| 0.001 | 17/06/2020 |
| 0.001 | 17/06/2020 |
| 0.004 | 3/06/2020 |
| 0.003 | 3/06/2020 |
| 0.005 | 3/06/2020 |
| 0.004 | 3/06/2020 |
| 0.004 | 3/06/2020 |
| 0.005 | 18/05/2020 |
| 0.002 | 18/05/2020 |
| 0.003 | 18/05/2020 |
| 0.002 | 18/05/2020 |
| 0.003 | 18/05/2020 |
| 0.005 | 14/05/2020 |
| 0.003 | 14/05/2020 |
| 0.006 | 14/05/2020 |
| 0.003 | 14/05/2020 |
| 0.010 | 14/05/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.011 | 13/05/2020 |
| 0.001 | 13/05/2020 |
| 0.001 | 13/05/2020 |
| 0.013 | 6/05/2020 |
| 0.001 | 6/05/2020 |
| 0.002 | 6/05/2020 |
| 0.007 | 6/05/2020 |
| 0.005 | 6/05/2020 |
| 0.009 | 6/05/2020 |
| 0.007 | 6/05/2020 |
| 0.017 | 6/05/2020 |
| 0.014 | 29/04/2020 |
| 0.001 | 29/04/2020 |
| 0.002 | 29/04/2020 |
| 0.006 | 29/04/2020 |
| 0.003 | 29/04/2020 |
| 0.006 | 29/04/2020 |
| 0.004 | 29/04/2020 |
| 0.007 | 29/04/2020 |
| 0.015 | 23/04/2020 |
| 0.001 | 23/04/2020 |
| 0.002 | 23/04/2020 |
| 0.006 | 22/04/2020 |
| 0.002 | 22/04/2020 |
| 0.004 | 22/04/2020 |
| 0.003 | 22/04/2020 |
| 0.005 | 22/04/2020 |
| 0.020 | 15/04/2020 |
| 0.001 | 15/04/2020 |
| 0.002 | 15/04/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.007 | 15/04/2020 |
| 0.005 | 15/04/2020 |
| 0.009 | 15/04/2020 |
| 0.005 | 15/04/2020 |
| 0.009 | 15/04/2020 |
| 0.015 | 9/04/2020 |
| 0.001 | 9/04/2020 |
| 0.007 | 9/04/2020 |
| 0.005 | 9/04/2020 |
| 0.015 | 9/04/2020 |
| 0.006 | 9/04/2020 |
| 0.020 | 9/04/2020 |
| 0.020 | 8/04/2020 |
| 0.001 | 8/04/2020 |
| 0.003 | 8/04/2020 |
| 0.021 | 1/04/2020 |
| 0.001 | 1/04/2020 |
| 0.003 | 1/04/2020 |
| 0.023 | 31/03/2020 |
| 0.001 | 31/03/2020 |
| 0.003 | 31/03/2020 |
| 0.022 | 27/03/2020 |
| 0.001 | 27/03/2020 |
| 0.004 | 27/03/2020 |
| 0.022 | 26/03/2020 |
| 0.001 | 26/03/2020 |
| 0.003 | 26/03/2020 |
| 0.023 | 25/03/2020 |
| 0.001 | 25/03/2020 |
| 0.004 | 25/03/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.021 | 20/03/2020 |
| 0.001 | 20/03/2020 |
| 0.004 | 20/03/2020 |
| 0.013 | 20/03/2020 |
| 0.010 | 20/03/2020 |
| 0.012 | 20/03/2020 |
| 0.009 | 20/03/2020 |
| 0.012 | 20/03/2020 |
| 0.019 | 17/03/2020 |
| 0.001 | 17/03/2020 |
| 0.004 | 17/03/2020 |
| 0.012 | 17/03/2020 |
| 0.008 | 17/03/2020 |
| 0.009 | 17/03/2020 |
| 0.027 | 17/03/2020 |
| 0.013 | 17/03/2020 |
| 0.023 | 16/03/2020 |
| 0.022 | 16/03/2020 |
| 0.020 | 16/03/2020 |
| 0.033 | 16/03/2020 |
| 0.031 | 16/03/2020 |
| 0.031 | 16/03/2020 |
| 0.024 | 16/03/2020 |
| 0.023 | 16/03/2020 |
| 0.021 | 16/03/2020 |
| 0.012 | 16/03/2020 |
| 0.020 | 16/03/2020 |
| 0.008 | 16/03/2020 |
| 0.018 | 16/03/2020 |
| 0.019 | 16/03/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.012 | 16/03/2020 |
| 0.014 | 16/03/2020 |
| 0.013 | 16/03/2020 |
| 0.002 | 11/03/2020 |
| 0.017 | 11/03/2020 |
| 0.012 | 11/03/2020 |
| 0.015 | 11/03/2020 |
| 0.015 | 11/03/2020 |
| 0.024 | 11/03/2020 |
| 0.002 | 11/03/2020 |
| 0.042 | 11/03/2020 |
| 0.012 | 11/03/2020 |
| 0.017 | 11/03/2020 |
| 0.019 | 11/03/2020 |
| 0.019 | 11/03/2020 |
| 0.014 | 9/03/2020 |
| 0.010 | 9/03/2020 |
| 0.014 | 9/03/2020 |
| 0.025 | 9/03/2020 |
| 0.015 | 9/03/2020 |
| 0.020 | 5/03/2020 |
| 0.014 | 5/03/2020 |
| 0.026 | 5/03/2020 |
| 0.028 | 5/03/2020 |
| 0.023 | 5/03/2020 |
| 0.016 | 4/03/2020 |
| 0.010 | 4/03/2020 |
| 0.021 | 4/03/2020 |
| 0.006 | 4/03/2020 |
| 0.020 | 4/03/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.014 | 3/03/2020 |
| 0.015 | 3/03/2020 |
| 0.020 | 3/03/2020 |
| 0.010 | 3/03/2020 |
| 0.022 | 3/03/2020 |
| 0.014 | 2/03/2020 |
| 0.008 | 2/03/2020 |
| 0.019 | 2/03/2020 |
| 0.018 | 2/03/2020 |
| 0.016 | 2/03/2020 |
| 0.014 | 27/02/2020 |
| 0.005 | 27/02/2020 |
| 0.017 | 27/02/2020 |
| 0.015 | 27/02/2020 |
| 0.026 | 27/02/2020 |
| 0.009 | 27/02/2020 |
| 0.012 | 27/02/2020 |
| 0.018 | 19/02/2020 |
| 0.052 | 19/02/2020 |
| 0.018 | 19/02/2020 |
| 0.034 | 19/02/2020 |
| 0.02 | 19/02/2020 |
| 0.03 | 19/02/2020 |
| 0.018 | 19/02/2020 |
| 0.057 | 12/02/2020 |
| 0.025 | 12/02/2020 |
| 0.009 | 12/02/2020 |
| 0.033 | 12/02/2020 |
| 0.02 | 12/02/2020 |
| 0.082 | 5/02/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.08 | 5/02/2020 |
| 0.07 | 5/02/2020 |
| 0.033 | 5/02/2020 |
| 0.046 | 5/02/2020 |
| 0.081 | 5/02/2020 |
| 0.099 | 5/02/2020 |
| 0.102 | 5/02/2020 |
| 0.013 | 5/02/2020 |
| 0.083 | 5/02/2020 |
| 0.043 | 5/02/2020 |
| 0.027 | 5/02/2020 |
| 0.014 | 5/02/2020 |
| 0.045 | 5/02/2020 |
| 0.08 | 29/01/2020 |
| 0.081 | 29/01/2020 |
| 0.078 | 29/01/2020 |
| 0.04 | 29/01/2020 |
| 0.062 | 29/01/2020 |
| 0.082 | 29/01/2020 |
| 0.068 | 29/01/2020 |
| 0.097 | 29/01/2020 |
| 0.015 | 29/01/2020 |
| 0.083 | 29/01/2020 |
| 0.048 | 29/01/2020 |
| 0.031 | 29/01/2020 |
| 0.031 | 29/01/2020 |
| 0.082 | 24/01/2020 |
| 0.081 | 24/01/2020 |
| 0.06 | 24/01/2020 |
| 0.013 | 24/01/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.042 | 24/01/2020 |
| 0.086 | 24/01/2020 |
| 0.043 | 24/01/2020 |
| 0.099 | 24/01/2020 |
| 0.014 | 24/01/2020 |
| 0.084 | 24/01/2020 |
| 0.063 | 24/01/2020 |
| 0.053 | 24/01/2020 |
| 0.023 | 24/01/2020 |
| 0.047 | 24/01/2020 |
| 0.085 | 22/01/2020 |
| 0.055 | 22/01/2020 |
| 0.043 | 22/01/2020 |
| 0.086 | 20/01/2020 |
| 0.052 | 20/01/2020 |
| 0.037 | 20/01/2020 |
| 0.036 | 20/01/2020 |
| 0.057 | 20/01/2020 |
| 0.086 | 17/01/2020 |
| 0.052 | 17/01/2020 |
| 0.043 | 17/01/2020 |
| 0.035 | 17/01/2020 |
| 0.050 | 17/01/2020 |
| 0.084 | 16/01/2020 |
| 0.048 | 16/01/2020 |
| 0.038 | 16/01/2020 |
| 0.03 | 16/01/2020 |
| 0.053 | 16/01/2020 |
| 0.080 | 15/01/2020 |
| 0.057 | 15/01/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.052 | 15/01/2020 |
| 0.025 | 15/01/2020 |
| 0.057 | 15/01/2020 |
| 0.084 | 14/01/2020 |
| 0.058 | 14/01/2020 |
| 0.026 | 14/01/2020 |
| 0.055 | 14/01/2020 |
| 0.052 | 14/01/2020 |
| 0.090 | 14/01/2020 |
| 0.059 | 14/01/2020 |
| 0.087 | 14/01/2020 |
| 0.021 | 14/01/2020 |
| 0.020 | 14/01/2020 |
| 0.089 | 13/01/2020 |
| 0.063 | 13/01/2020 |
| 0.070 | 13/01/2020 |
| 0.041 | 13/01/2020 |
| 0.040 | 13/01/2020 |
| 0.097 | 8/01/2020 |
| 0.057 | 8/01/2020 |
| 0.060 | 8/01/2020 |
| 0.028 | 8/01/2020 |
| 0.105 | 7/01/2020 |
| 0.05 | 7/01/2020 |
| 0.062 | 7/01/2020 |
| 0.038 | 7/01/2020 |
| 0.064 | 7/01/2020 |
| 0.1 | 7/01/2020 |
| 0.046 | 7/01/2020 |
| 0.086 | 7/01/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|-----------|
| 0.033 | 7/01/2020 |
| 0.059 | 7/01/2020 |
| 0.09 | 6/01/2020 |
| 0.089 | 6/01/2020 |
| 0.096 | 6/01/2020 |
| 0.095 | 3/01/2020 |
| 0.098 | 3/01/2020 |
| 0.096 | 3/01/2020 |
| 0.071 | 3/01/2020 |
| 0.022 | 3/01/2020 |
| 0.096 | 3/01/2020 |
| 0.12 | 3/01/2020 |
| 0.012 | 3/01/2020 |
| 0.081 | 3/01/2020 |
| 0.073 | 3/01/2020 |
| 0.076 | 3/01/2020 |
| 0.052 | 3/01/2020 |
| 0.045 | 3/01/2020 |
| 0.101 | 6/01/2020 |
| 0.08 | 3/01/2020 |
| 0.074 | 3/01/2020 |
| 0.067 | 3/01/2020 |
| 0.055 | 3/01/2020 |
| 0.038 | 3/01/2020 |
| 0.09 | 2/01/2020 |
| 0.095 | 2/01/2020 |
| 0.068 | 2/01/2020 |
| 0.060 | 2/01/2020 |
| 0.048 | 2/01/2020 |
| 0.043 | 2/01/2020 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.064 | 2/01/2020 |
| 0.069 | 2/01/2020 |
| 0.064 | 2/01/2020 |
| 0.001 | 2/01/2020 |
| 0.046 | 2/01/2020 |
| 0.091 | 2/01/2020 |
| 0.068 | 2/01/2020 |
| 0.066 | 2/01/2020 |
| 0.043 | 2/01/2020 |
| 0.054 | 2/01/2020 |
| 0.004 | 30/12/2019 |
| 0.108 | 30/12/2019 |
| 0.101 | 30/12/2019 |
| 0.066 | 30/12/2019 |
| 0.032 | 30/12/2019 |
| 0.114 | 30/12/2019 |
| 0.101 | 30/12/2019 |
| 0.099 | 30/12/2019 |
| 0.015 | 30/12/2019 |
| 0.096 | 30/12/2019 |
| 0.075 | 30/12/2019 |
| 0.067 | 30/12/2019 |
| 0.054 | 30/12/2019 |
| 0.064 | 30/12/2019 |
| 0.098 | 30/12/2019 |
| 0.073 | 30/12/2019 |
| 0.071 | 30/12/2019 |
| 0.055 | 30/12/2019 |
| 0.071 | 30/12/2019 |
| 0.092 | 30/12/2019 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.071 | 30/12/2019 |
| 0.074 | 30/12/2019 |
| 0.055 | 30/12/2019 |
| 0.067 | 30/12/2019 |
| 0.101 | 24/12/2019 |
| 0.071 | 24/12/2019 |
| 0.072 | 24/12/2019 |
| 0.063 | 24/12/2019 |
| 0.076 | 24/12/2019 |
| 0.095 | 24/12/2019 |
| 0.081 | 24/12/2019 |
| 0.082 | 24/12/2019 |
| 0.058 | 24/12/2019 |
| 0.08 | 24/12/2019 |
| 0.09 | 24/12/2019 |
| 0.085 | 24/12/2019 |
| 0.079 | 24/12/2019 |
| 0.059 | 24/12/2019 |
| 0.068 | 24/12/2019 |
| 0.085 | 23/12/2019 |
| 0.076 | 23/12/2019 |
| 0.073 | 23/12/2019 |
| 0.06 | 23/12/2019 |
| 0.059 | 23/12/2019 |
| 0.071 | 20/12/2019 |
| 0.087 | 20/12/2019 |
| 0.056 | 20/12/2019 |
| 0.047 | 20/12/2019 |
| 0.052 | 20/12/2019 |
| 0.086 | 19/12/2019 |

Uralla Town Water Arsenic Test Data - By Test Date

| Total Arsenic Result (mg/L) | Test date |
|-----------------------------|------------|
| 0.089 | 19/12/2019 |
| 0.07 | 19/12/2019 |
| 0.122 | 19/12/2019 |
| 0.001 | 19/12/2019 |
| 0.085 | 19/12/2019 |
| 0.1 | 19/12/2019 |
| 0.1 | 19/12/2019 |
| 0.009 | 19/12/2019 |
| 0.081 | 17/12/2019 |
| 0.057 | 17/12/2019 |
| 0.047 | 17/12/2019 |
| 0.047 | 17/12/2019 |
| 0.072 | 13/12/2019 |
| 0.050 | 13/12/2019 |
| 0.037 | 13/12/2019 |
| 0.044 | 13/12/2019 |
| 0.051 | 13/12/2019 |
| 0.052 | 13/12/2019 |
| 0.039 | 13/12/2019 |
| 0.042 | 13/12/2019 |
| 0.042 | 4/12/2019 |
| <0.001 | 14/08/2019 |