## **GENERAL ELEVATION NOTES**

ALL GLASS & GLAZING SHALL BE IN ACCORDANCE WITH PART 3.6 GLAZING, NCC VOL2 AND AS1288-2006 GLASS IN BUILDINGS - SELECTION AND INSTALLATION

ALL STAIRS TO BE IN ACCORDANCE WITH PART 3.9.1, NCCVOL2.

BALUSTRADE TO BE MINIMUM 1000MM ABOVE FFL WITH NO OPENINGS GREATER THAN 124MM IN ACCORDANCE WITH PART 3.9.2, NCC VOL2.


40mm ALLOWANCE TO CEILING HEIGHT FOR CEILING BATTENS & PLASTERBOARD.

JAMES HARDIES VERSILUX™ CEILING WITH 18x18 PERIMETER BEAD PROVIDED TO EXTERNAL CEILINGS (ALFRESCO & PORCH ONLY, UNO).

UPPER FLOOR WINDOWS TO COMPLY WITH REQUIREMENTS OF NCC VOL 2 3.9.2.5 INCLUDING WINDOWS MARKED 'RESTRICT', 'SCREEN' OR 'LOCK'







**Elevation B** 

1:100

## **GENERAL ELEVATION NOTES**

ALL GLASS & GLAZING SHALL BE IN ACCORDANCE WITH PART 3.6 GLAZING, NCC VOL2 AND AS1288-2006 GLASS IN BUILDINGS - SELECTION AND INSTALLATION


ALL STAIRS TO BE IN ACCORDANCE WITH PART 3.9.1, NCCVOL2.


BALUSTRADE TO BE MINIMUM 1000MM ABOVE FFL WITH NO OPENINGS GREATER THAN 124MM IN ACCORDANCE WITH PART 3.9.2, NCC VOI 2


40mm ALLOWANCE TO CEILING HEIGHT FOR CEILING BATTENS & PLASTERBOARD.

JAMES HARDIES VERSILUX™ CEILING WITH 18x18 PERIMETER BEAD PROVIDED TO EXTERNAL CEILINGS (ALFRESCO & PORCH ONLY, UNO).

UPPER FLOOR WINDOWS TO COMPLY WITH REQUIREMENTS OF NCC VOL 2 3.9.2.5 INCLUDING WINDOWS MARKED 'RESTRICT', 'SCREEN' OR 'LOCK'







**Elevation D** 

1:100